

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Recessed LED Panel – 30-Medica Eco

Name and address of the applicant

LITETECH INDUSTRIES LLC
RAS AL KHOR INDUSTRIAL AREA
STREET NO:13B
AL AWEER
DUBAI
United Arab Emirates

Name and address of the manufacturer

LITETECH INDUSTRIES LLC
RAS AL KHOR INDUSTRIAL AREA
STREET NO:13B
AL AWEER
DUBAI
United Arab Emirates

Name and address of the factory


Note: When more than one factory, please report on page 2

 Additional information on page 2
LITETECH INDUSTRIES LLC
RAS AL KHOR INDUSTRIAL AREA
STREET NO:13B
AL AWEER
DUBAI
United Arab Emirates

Ratings and principal characteristics

Protection class: Class I;
Protection against dust, solid object and moisture: IP65;
Suitable for surface: Suitable to be mounted on normally flammable surfaces;
cannot be covered with thermal insulating material
Classification of use: For normal use;
Construction: CRCA steel sheet body, Aluminium frame, plastic diffuser;
Supply connection: Terminal block;
Used lamp: LED module, Non-user replaceable;
Ratings: 220-240V, 50/60Hz, 40W LED Module;
Weight: 3.85kg;
Dimensions: 595x595x65 (mm)

Trademark (if any)



LITE-TECH

LITE-TECH

Customer's Testing Facility (CTF) Stage used

This CB Test Certificate is issued by the National Certification Body

LIA Laboratory Limited
Stafford Park 7, Telford, Shropshire TF3 3BQ, United KingdomtheLIA
Laboratory

Signature: Tariq Malik

Date: 2021-07-06

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

Model / Type Ref.

30-Medica Eco-LTS40-8yy, 30-Medica Eco-LTS36-8yy, 30-Medica Eco-LTS40-8yy-Dali,
30-Medica Eco-LTS36-8yy-Dali, 30-Medica Eco-LTS40-8yy-1-10V, 30-Medica
Eco-LTS36-8yy-1-10V, 30-Medica Eco-LTP40-8yy, 30-Medica Eco-LTP36-8yy,
30-Medica Eco-LTP40-8yy-Dali, 30-Medica Eco-LTP36-8yy-Dali, 30-Medica
Eco-LTP40-8yy-1-10V, 30-Medica Eco-LTP36-8yy-1-10V

Additional information (if necessary may also be
reported on page 2) Additional information on page 2

Product code explanation:

Fixture name: 30-Medica Eco-LTxww-8yy-####

Family name – 30-Medica Eco

LTx – LED chip - LTS / LTP – Samsung / Lumiled

ww – Wattage – 36 / 40 – 36W / 40W

8yy – CRI and CCT - CRI>80, yy – 30/40/65 - 3000K / 4000K / 6500K

(####) – Dimmable control gear – DALI / 1-10V – DALI / Dimming 1-10V

A sample of the product was tested and found
to be in conformity with

IEC 60598-1:2014/AMD1:2017, IEC 60598-2-2:2011

As shown in the Test Report Ref. No. which
forms part of this Certificate

National differences:

AE, BH, JO, KW, OM, QA, SA

CB1143

This CB Test Certificate is issued by the National Certification Body

LIA Laboratory Limited
Stafford Park 7, Telford, Shropshire TF3 3BQ, United KingdomtheLIA
Laboratory

Signature: Tariq Malik

Date: 2021-07-06