

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Recessed LED Panel – 30-Medica-P

Name and address of the applicant

LITETECH INDUSTRIES LLC
RAS AL KHOR INDUSTRIAL AREA
STREET NO:13B
AL AWEER
DUBAI
United Arab Emirates

Name and address of the manufacturer

LITETECH INDUSTRIES LLC
RAS AL KHOR INDUSTRIAL AREA
STREET NO:13B
AL AWEER
DUBAI
United Arab Emirates

Name and address of the factory


Note: When more than one factory, please report on page 2

 Additional information on page 2
LITETECH INDUSTRIES LLC
RAS AL KHOR INDUSTRIAL AREA
STREET NO:13B
AL AWEER
DUBAI
United Arab Emirates

Ratings and principal characteristics

Protection class: Class I;
Protection against dust, solid object and moisture: IP65;
Suitable for surface: Suitable to be mounted on normally flammable surfaces;
cannot be covered with thermal insulating material
Classification of use: For normal use;
Construction: CRCA steel sheet body, Aluminium frame, plastic diffuser;
Supply connection: Terminal block;
Used lamp: LED module, Non-user replaceable;
Ratings: 220-240V, 50/60Hz, 40W LED Module;
Weight: 6.74kg;

Trademark (if any)



LITE-TECH

LITE-TECH

Customer's Testing Facility (CTF) Stage used

This CB Test Certificate is issued by the National Certification Body

LIA Laboratory Limited
Stafford Park 7, Telford, Shropshire TF3 3BQ, United KingdomtheLIA
Laboratory

Signature: Tariq Malik

Date: 2021-07-09

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

Model / Type Ref.

30-MEDICA-P-LTb40 /z, 30-MEDICA-P-LTb36 /z, 30-MEDICA-P-LTb40-DALI /z,
30-MEDICA-P-LTb36-DALI /z, 30-MEDICA-P-LTb40-1-10V /z, 30-MEDICA-P-LTb36-1-10V
/z, 30-MEDICA-P-DSb40 /z, 30-MEDICA-P-DSb36 /z, 30-MEDICA-P-DSb40-DALI /z,
30-MEDICA-P-DSb36-DALI /z, 30-MEDICA-P-DSb40-1-10V /z, 30-Medica-P-DSb36-1-10V
/z

Additional information (if necessary may also be reported on page 2)

 Additional information on page 2

Product code explanation

Example: 30-Medica-P-LTS40-865-DALI /M

Fixture name: 30-Medica-P-aabcc-8dd- ee /z

30-Medica-P - Family name

aa – Linear module (85mm height) / Double square module (110mm height) – LT / DS

b – LED chip - S / P – Samsung / Lumiled

cc – Wattage - 36 / 40 – 36W / 40W

8dd – CRI and CCT CRI>80

dd – 30/40/65 - 3000K / 4000K / 6500K

ee – (if required) Dimmable control gear – DALI / 1-10V – DALI / Dimming 1-10V

/z – (if required) type of mounting – no symbol / M – Lay-in-ceiling (595mmx595mm) / Clip-in ceiling (599mmx599mm)

A sample of the product was tested and found to be in conformity with

IEC 60598-1:2014/AMD1:2017, IEC 60598-2-2:2011

National differences:

AE, BH, JO, KW, OM, QA, SA

As shown in the Test Report Ref. No. which forms part of this Certificate

CB1144

This CB Test Certificate is issued by the National Certification Body

LIA Laboratory Limited
Stafford Park 7, Telford, Shropshire TF3 3BQ, United KingdomtheLIA
Laboratory

Signature: Tariq Malik

Date: 2021-07-09

page 2 of 2